

**GOVERNMENT OF ANDHRA PRADESH  
FIRE AND EMERGENCY SERVICES DEPARTMENT**

From

Sri V. Sreenivasa Reddy, M.Sc.  
D.F.E.  
District Fire Officer, Chittoor

To

The Secretary  
Siddartha Educational Academy Group of  
Institutions-Integrated Campus for  
Engineering & MBA, Sy.No.134 (P),  
Chinthagunta Village,  
Sanambatla Panchayat  
Chandragiri Mandal of Chittoor Dist.

Rc.No.053/DFO/CTR/2016, dated 20-01-2016

Sir,

Sub:- A.P. Fire and Emergency Services Department – Southern Region – Chittoor District – Tirupati Fire Station – Issue of Issuance of No Objection Certificate for Multistoried building of **Siddartha Educational Academy Group of Institutions-Integrated Campus for Engineering & MBA, Sy.No.134 (P) Chinthagunta Village, Sanambatla Panchayat, Chandragiri Mandal of Chittoor District** – Regarding.

- Ref:
1. Letter from the **Secretary, Siddartha Educational Academy Group of Institutions-Integrated Campus for Engineering & MBA, Sy.No.134 (P) Chinthagunta Village, Sanambatla Panchayat, Chandragiri Mandal of Chittoor District**. Dt.21-12-2015.
  2. Inspection report of the Station Fire Officer, Tirupati Lr.Rc.No.09/TPT/ 2016, dt 08-01-2016 with Endt. No. - of the Assistant District Fire Officer, Chittoor.
  3. Section 13(2) of A.P. Fire Services Act, 1999 and Rule 15(2) of A.P. Fire and Emergency Operations and Levy of Fee Rules, 2006.
  4. Chief Office Memo Rc.No.2305/B2/2007 dt.28-02-2007 & dt.12-09-2008

\* \* \* \* \*

In obedience to the instructions issued by the Director General of Fire & Emergency Services, A.P., Hyderabad vide ref. 4<sup>th</sup> cited and in compliance to the authorization given in accordance with reference 3<sup>rd</sup> cited, and as per the recommendation of the Station Fire Officer, Tirupati report submitted vide reference 2<sup>nd</sup> cited, the No Objection Certificate is issued to the Multistoried Building with a height of 12.06 mtrs. for existing Educational Building with Ground Floor +2 Upper Floors only of **Siddartha Educational Academy Group of Institutions-Integrated Campus for Engineering & MBA, Sy.No.134 (P) Chinthagunta Village, Sanambatla Panchayat, Chandragiri Mandal of Chittoor District**.

2(A) Particulars of the Building:

- a) Address of the Building : **Secretary, Siddartha Educational Academy Group of Institutions-Integrated Campus for Engineering & MBA, Sy.No.134 (P) Chinthagunta Village, Sanambatla Panchayat, Chandragiri Mandal of Chittoor District.**
- b) Area of Plot /Ht of Bldg. : 11 acres / 12.06 mtrs.
- c) No. of Blocks / Floors : 01Block /Ground + 2 Upper Floors Only
- d) Type of Occupancy : Educational – B2
- e) Floor-wise details:

Sl. No.	Floors	Builtup Area in Sq. mts.	Occupancy (Educational / Hostel/Dormitory Occupancy/	Occupant load
1.	Ground Floor	7072.00	Educational	1500
2.	1 <sup>st</sup> Floor	7072.00		
3.	2 <sup>nd</sup> Floor	7072.00		
Total		21216.00		

- f) Smoke Venting facilities for safe use of exists shall be provided as per Clause 3, 4:2 Part 4 National Building Code of India, 2005
- g) The following fire fighting systems shall be provided by the builder as per Table – 23 of N:B Part-IV.

Contd. ...2

- 1) Fire extinguishers as per IS: 2190 are already provided.
  - (a) Two 9 liters Water expelling extinguishers and one 4.5 kg. CO<sub>2</sub> extinguishers and one 5 Kgs. DCP Extinguisher for every 600 sq.mts. radius.
  - (b) Four 9 Liters. round bottom Fire Buckets (Two filled with water and two filled with dry sand) For every 600 sq.mts, built up area / per floor should be hung to a stand.


**NOTE:**

- Fire extinguishers should be placed as near as possible to exits of stair lands with out hindering the routes.
- Wall mounted Fire extinguishers should be placed on the supporting wall or in wooden, metal or plastic, cabinets, in such a way that their bottom is 1000 MM above ground level.

The No Objection Certificate is issued subject to the following conditions

- (i) All the Fire safety measures as advised above should be provided without fail. No temporary structure such as tents or with thatched construction shall be allowed for educational institutions
  - (ii) Every room with a capacity of 45 students shall have at least two doors.
- h) Any alterations or expansion of the building should be informed to the undersigned and get permission.
- i) The bullder may be informed of the following rules and regulations.
- 1) As per clause 13:1 of Part-II of the National building code of India neither guarantying or the permit nor the approval of the drawings and specifications. Nor inspections made by the Authority during erection of the building shall in any way relieve the owner of such building, from full responsibility for carrying out the work in accordance with the requirements of National Building Code of India.
  - 2) As per clause 9.3 of part-II of the National Building Code of India the Licensed Architect/Engineer/Structural/Supervisor/ Town planner shall be responsible for supervision of the construction and for the compellation certificate. In the event of violation of the provisions of the code shall be liable to penalties as prescribed by the Authorities including cancellation of the license.

The Secretary, Siddartha Educational Academy Group of Institutions-Integrated Campus for Engineering & MBA, Sy.No.134 (P) Chinthagunta Village, Sanambatia Panchayat, Chandragiri Mandal of Chittoor District., has remitted Challan for Rs. 71,770-00 (Rupees Seventy One Thousand Seven Hundred and Seventy only) vide Challan No. 64515 dt. 04-01-2016 towards Fire precaution fee in Sub-Treasury, S.B.I., Tirupati Branch for total built up area.

  
District Fire Officer,  
Chittoor

**Copies to:**

1. Copy submitted to the Director General of Fire & Emergency Services, A.P., Hyderabad for favour of kind information.
2. Copy submitted to the Regional Fire Officer, S.R., Hyderabad.
3. Copy to the Asst. District Fire Officer, Chittoor.
4. Copy to the Station Fire Officer, Tirupati.
5. NOC copy to The Secretary, Siddartha Educational Academy Group of Institutions-Integrated Campus for Engineering & MBA, Sy.No.134 (P) Chinthagunta Village, Sanambatia Panchayat, Chandragiri Mandal of Chittoor District.,